



NO CONCRETE REQUIRED  
ON STANDARD SERVICE  
CONNECTIONS UNLESS  
WYE WAS OMITTED AND  
TAPPING SADDLE IS USED

NOTE: COMPACT TO MINIMUM OF 95%  
STANDARD PROCTOR ONE FOOT  
EITHER SIDE OF SERVICE CONNECTION.



**CITY OF CORDELE, GEORGIA - STANDARD DETAIL**

STANDARD SERVICE  
CONNECTION

DETAIL NO:

S-010

DATE: