



150 PSI TEST PRESSURE  
2000 PSF SOIL BEARING

BLOCKING DIMENSIONS						
DEAD END & TEES	X*	A	B	C	D	
	16"	1'-3"	3'-6"	7'-6"	4'-9"	4'-9"
12"	1'-0"	3'-0"	5'-6"	3'-0"	3'-0"	
10"	1'-0"	2'-6"	4'-9"	3'-0"	3'-0"	
8"	0'-10"	2'-0"	4'-0"	2'-6"	2'-6"	
6"	0'-8"	1'-6"	2'-9"	1'-9"	1'-9"	
BENDS	90°	16"	1'-3"	5'-6"	9'-0"	5'-6"
		12"	1'-0"	4'-0"	6'-9"	4'-3"
		10"	1'-0"	3'-0"	5'-9"	3'-6"
		8"	0'-10"	2'-6"	4'-9"	3'-0"
		6"	0'-8"	1'-6"	3'-6"	2'-9"
	45°	16"	1'-3"	3'-6"	6'-9"	4'-3"
		12"	1'-0"	2'-3"	5'-3"	3'-3"
		10"	1'-0"	2'-3"	4'-6"	2'-9"
		8"	0'-10"	1'-6"	3'-6"	2'-3"
		6"	0'-8"	1'-3"	2'-6"	1'-6"
	22 1/2°	16"	1'-3"	1'-6"	4'-9"	3'-0"
		12"	1'-0"	1'-6"	3'-6"	2'-3"
		10"	1'-0"	1'-3"	3'-0"	2'-0"
		8"	0'-10"	1'-0"	2'-6"	1'-6"
		6"	0'-8"	1'-0"	1'-9"	1'-3"
	11 1/4°	16"	1'-3"	1'-6"	3'-3"	2'-0"
12"		1'-0"	1'-6"	2'-6"	1'-6"	
10"		1'-0"	1'-0"	2'-3"	1'-3"	
8"		0'-10"	1'-0"	1'-9"	1'-0"	
6"	0'-8"	1'-0"	1'-6"	0'-6"		

X\* = DIAMETER OF PIPE TO BE BLOCKED

TYPICAL BLOCKING

N.T.S.



**CITY OF CORDELE, GEORGIA - STANDARD DETAIL**

THRUST BLOCK DETAIL "A"

DETAIL NO:

W-003A

DATE: