



STANDARD
TYPE A-24"

NOTES:

1. VALLEY GUTTER TO BE CONSTRUCTED IN 10 FOOT LENGTHS.
2. 1/2" EXPANSION JOINTS SHALL BE PROVIDED AT INTERVALS NOT TO EXCEED 50 FEET AT THE ENDS AND MID-POINTS OF RETURNS, AND AT ANY POINT WHERE THE NEW VALLEY GUTTER ABUTS OTHER CONCRETE STRUCTURES.



CITY OF CORDELE, GEORGIA - STANDARD DETAIL

VALLEY GUTTER

DETAIL NO:

P-012

DATE: