



- SECTION VIEW
1. PRECAST MANHOLE SECTIONS TO BE MFRD. IN ACCORDANCE WITH THE LATEST EDITIONS OF A.S.T.M. C-478 WITH 4000 LB. CONC., TYPE II CEMENT.
 2. THE INTERIOR AND EXTERIOR OF MANHOLE SHALL BE GIVEN TWO COATS OF FARBERTITE BITUMINOUS WATERPROOFING MATERIAL DO NOT COAT JOINT OR PIPE OPENING SURFACES.

NOTE: SOME PARTS OF THIS DETAIL MAY BE MODIFIED WITH APPROVAL FROM THE SEWER SUPERINTENDENT.



CITY OF CORDELE, GEORGIA - STANDARD DETAIL

INSIDE DROP PRECAST MANHOLE

DETAIL NO:

S-004

DATE: